

## Fire Department Water Tanker Shuttle Accreditation

Presented To: The Nation Municipality

### ACCREDITED FIRE STATIONS

F.S #100 St-Isidore (6)  
F.S #200 St-Bernardin (6)  
F.S #300 Fournier (6)  
F.S #400 St-Albert (6)  
F.S #500 Limoges (6)

Date Test Passed: September 6<sup>th</sup> 2019

Flow Achieved: 626 I.G.P.M. 2,850 LITERS/MIN.

Two (2) Hour Test Time



Signed: Elaine Rose  
Elaine Rose  
Partner

This Certificate Expires on: September 1<sup>st</sup> 2024