



Report to Council

Report Number: WS-06-2023

Subject: Valve chamber in Forest Park

Prepared by: Nicholas Pigeon CET, Director of Water and Wastewater (acting)

Reviewed by: Nadia (Lockhart) Knebel, Treasurer

Reviewed by: Josée Brizard, Chief Administrative Officer / Clerk

Date of the meeting: July 24th, 2023

CONTEXT

This project was designed by EXP, the purpose is to have a control on the water distribution pressure in Limoges. There is only a 3 in pipe with a regular check valve, in between Forest Park and Limoges. The pressure in Limoges can not be adjusted higher without affecting the pressure in Forest Park. With the flow raising every year in Limoges this is a must to be able to maintain an adequate pressure for the village of Limoges. We would like to propose this project to be performed at the earliest.

FINACIAL CONSIDERATIONS

Contractors were invited to submit a price for the above project, on Bids and Tender.

We received three bids:

Bidders	BID \$ (not including HST)	Date & Time - BY EMAIL
Black and MacDonald	151 550 \$	11:00 am – July 19 th
Pro Pipe Construction	114 032 \$	11:00 am – July 19 th
Coalwater	239 319 \$	2:30 pm – July 19 th

I recommend moving forward with Pro Pipe Construction. Since this is an unexpected capital project, it was not included in the 2023 budget. The budget includes an amount of \$200,000 for the design of Phase II with Rockland. These funds will not be used in 2023 since the start of the design was delayed. It is proposed to use part of this amount to fund this project with the balance to be used for the start of the Limoges water and sewer master plan.

RECOMMENDATION

It is recommended that Council approve the construction upgrades of the Limoges Valve Chamber in Forest Park with the funds being taken from the reserve as explained above.